

VOC Content Test Certificate

Monday 14th August 2023

Supplier: Selleys Pty Ltd (1 Gow Street, PADSTOW, NSW 2211, AUSTRALIA).

Product Name: Selleys No More Gaps Interior Multipurpose

Date Tested: 8th August 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Selleys No More Gaps Interior Multipurpose
General Purpose Adhesives and Sealants: 50 grams per litre	12 grams per litre as VOC content per material
<i>We hereby certify Selleys No More Gaps Interior Multipurpose is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant